

# CERTIFICATE of Conformity



Registration No.: AK 50538793 0001

Report No.: CN22EOEK 001

**Holder:** Guangzhou Sanjing Electric Co., Ltd.  
No.9, Lizhishan Road, Science City,  
Guangzhou High-tech Zone,  
Guangdong  
P.R. China

**Product:** PV-Inverter  
Grid-Connected PV Inverter

**Identification:** Type Designation: R6-15K-T2-32, R6-17K-T2-32, R6-20K-T2-32,  
R6-22K-T2-32, R6-25K-T2-32  
Serial No. : R6T2503G2112E00002  
Firmware version: V1.020  
Remark: Refer to test report CN22EOEK 001 for details.

**Tested acc. to:** UNE 206006 IN:2011  
UNE 206007-1 IN:2013  
RD 1699:2011  
RD 661:2007  
RD 413:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 30.03.2022

A handwritten signature in blue ink, appearing to read 'A. Chen'.  
A. Chen

**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

Guangzhou Sanjing Electric Co.,  
Ltd.

Date : 30/03/2022  
Our ref. : 02  
Your ref.: 168346650

No.9, Lizhishan Road, Science City,  
Guangzhou High-tech Zone,  
Guangdong  
P.R. China

**Ref : AK Certificate of Conformity**

Type of Equipment : Grid-Connected PV Inverter  
Model Designation : See Certificate  
Certificate No. : AK 50538793 0001  
Report No. : CN22EOEK 001

Dear Ladies and Gentlemen,


We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

  
A. Chen

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

**C E R T I F I C A T E**  
of Conformity  
EC Council Directive 2014/30/EU  
Electromagnetic Compatibility

Registration No.: AE 50538832 0001

Report No.: CN21ESNZ 001

Holder: Guangzhou Sanjing Electric Co., Ltd.  
No.9, Lizhishan Road, Science City,  
Guangzhou High-tech Zone,  
Guangdong  
P.R. China

Product: PV-Inverter  
(Grid-connected PV Inverter)

Identification: R6-15K-T2-32 R6-17K-T2-32 R6-20K-T2-32  
R6-22K-T2-32 R6-25K-T2-32 R6-5K-T2-32-LV  
R6-6K-T2-32-LV R6-8K-T2-32-LV R6-10K-T2-32-LV  
R6-15K-T2-32-LV  
Serial No.: n.a.

Remark: Refer to above-listed test report for details.

Tested acc. to: EN IEC 61000-6-2:2019  
EN IEC 61000-6-4:2019

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2014/30/EU. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to the a.m. Directive.

Date 31.03.2022



Certification Body



Tongle Lee

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Guangzhou Sanjing Electric Co.,  
Ltd.

Date : 31.03.2022  
Our ref. : AOFEL 02  
Your ref.:

No.9, Lizhishan Road, Science City,  
Guangzhou High-tech Zone,  
Guangdong  
P.R. China

**Ref : AE Certificate of Conformity EMC**

Type of Equipment : Grid-connected PV Inverter  
Model Designation : See Certificate  
Certificate No. : AE 50538832 0001  
Report No. : CN21ESNZ 001

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Tongle Lee

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

# CERTIFICATE



## of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50542094 0001

Report No.: CN22SWUP 001

**Holder:** Guangzhou Sanjing Electric Co., Ltd.  
No.9, Lizhishan Road, Science City,  
Guangzhou High-tech Zone,  
Guangdong  
P.R. China

**Product:** PV-Inverter  
(Grid-connected PV Inverter)

**Identification:** Type Designation: R6-25K-T2-32, R6-22K-T2-32, R6-20K-T2-32,  
R6-17K-T2-32, R6-15K-T2-32, R6-15K-T2-32-LV,  
R6-10K-T2-32-LV, R6-8K-T2-32-LV,  
R6-6K-T2-32-LV, R6-5K-T2-32-LV  
Serial Number : Engineering samples  
Remark : Refer to test report CN22SWUP 001  
for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 28.04.2022

A handwritten signature in blue ink, appearing to read 'A. Chen'.  
A. Chen

**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

The CE marking, consisting of the letters 'C' and 'E' inside a circle.  
The CE marking may be used if all relevant and effective EC Directives are complied with.



Guangzhou Sanjing Electric Co.,  
Ltd.

Date : 28.04.2022  
Our ref. : 02  
Your ref.: 168346650

No.9, Lizhishan Road, Science City,  
Guangzhou High-tech Zone,  
Guangdong  
P.R. China

**Ref : AN Certificate of Conf. Low Voltage D.**

Type of Equipment : Grid-connected PV Inverter  
Model Designation : See Certificate  
Certificate No. : AN 50542094 0001  
Report No. : CN22SWUP 001

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

  
A. Chen

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

# Certificado de Conformidad

Número de Certificado: CN-PV-220133

Conforme a los ensayos realizados, la muestra<s> del producto que se detalla a continuación se ajusta a los requisitos de la especificación<s>/norma<s> de referencia en el momento en que se realizaron los ensayos. Esto no implica que Intertek haya realizado ningún tipo de vigilancia o control de la(s) fabricación(es). El o los fabricantes se asegurarán de que el proceso de fabricación cumpla con los productos examinados mencionados en este certificado.

<b>Solicitante:</b>	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
<b>Producto:</b>	Inversor Fotovoltaico Conectado a la Red
<b>Calificaciones y Características Principales:</b>	Véase el apéndice del Certificado de Conformidad
<b>Modelo:</b>	R6-15K-T2-32, R6-17K-T2-32, R6-20K-T2-32, R6-22K-T2-32, R6-25K-T2-32
<b>Nombre de la Marca&lt;s&gt;:</b>	
<b>Producto Conforme con:</b>	NTS-631:2020 Norma técnica para el control de conformidad de los módulos de generación de energía según el Reglamento UE 2016/631
<b>Nombre y Dirección de la Oficina Emisora del Certificado:</b>	Intertek Testing Services Ltd.Shanghai West Area, 2 <sup>nd</sup> Floor, No.707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P.R.China Acreditado por ACCREDIA de conformidad con la norma ISO/IEC 17065:2012
<b>Informe de la Prueba&lt;s&gt; N°:</b>	220614052GZU-001

Información Complementaria en el Apéndice.



Firma

Responsable de la Certificación: Grady  
Fecha: 06 de julio de 2022



PRD N° 306B

El presente Certificado está destinado al uso exclusivo del cliente de Intertek y se entrega en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad y la obligación de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente según el acuerdo, por cualquier pérdida, gasto, o daño ocasionado por el uso de este Certificado. Únicamente el Cliente está autorizado a conceder la copia o distribución de este Certificado. El uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto, o servicio examinado debe ser aprobado previamente por escrito por Intertek.

## APÉNDICE: Certificado de Conformidad

Este es un Apéndice del Certificado de Conformidad Número:CN-PV-220133.

Unidad / Tipo.....	R6-15K-T2-32	R6-17K-T2-32	R6-20K-T2-32	R6-22K-T2-32	R6-25K-T2-32
Versión de hardware / Número de serie (examinado).....	Main Power board: V1.3; Control board: V1.0				
Versión del firmware / Versión del software (examinado) .....	V1.020				
Rango de Corriente Continua MPP a plena carga [V].....	460-900	460-900	480-900	500-900	520-900
Rango de entrada de Corriente Continua [V].....	180-1000				
Entrada de Corriente Continua [A] .....	max.32A x 2				
ISC PV [A] .....	38,4A x 2				
Tensión nominal de salida de CA [V] .....	230/400V (3~ + N + PE, 50/60Hz)				
Salida máxima de Corriente Alterna [A] :	25.0	28.4	33.4	36.7	41.7
Potencia activa nominal de salida [kW] :	15	17	20	22	25
Potencia de salida máxima aparente [kVA] .....	16,5	18,7	22,0	24,2	27,5

El presente Certificado está destinado al uso exclusivo del cliente de Intertek y se entrega en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad y la obligación de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente según el acuerdo, por cualquier pérdida, gasto, o daño ocasionado por el uso de este Certificado. Únicamente el Cliente está autorizado a conceder la copia o distribución de este Certificado. El uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto, o servicio examinado debe ser aprobado previamente por escrito por Intertek.



## APÉNDICE: Certificado de Conformidad

Este es un Apéndice del Certificado de Conformidad Número: CN-PV-220133.

Requisito / Requirement	NTS	Tipo / Type	Cumplimiento / Complicant	Nombre Entidad Emisora / Name of issuing Entity	Ev.(*)
Modo regulación potencia-frecuencia limitado sobrefrecuencia (MRPFL-O) / Power-frequency regulation mode limited to overfrequency (MRPFL-O)	5.1	≥A	YES (TRF No.220614052GZ U-001)	Intertek	P
Modo regulación potencia-frecuencia limitado-subfrecuencia (MRPFL-U) / Power-frequency regulation mode limited to underfrequency (MRPFL-U)	5.2	≥C	NO APPLICABLE	--	--
Modo regulación potencia-frecuencia (MRPF) / Power-frequency regulation mode (MRPF)	5.3	≥C	NO APPLICABLE	--	--
Control de potencia-frecuencia / Frequency Control	5.4	≥C	NO APPLICABLE	--	--
Capacidad de control y el rango de control de la potencia activa en remote / Active Power Requirements	5.5	≥C	NO APPLICABLE	--	--
Emulación de inercia durante variaciones de frecuencia muy rápidas / Inertia Emulations	5.6	≥C	NO APPLICABLE	--	--
Capacidad de potencia reactiva a la capacidad máxima y por debajo / Reactive power capabilities at the EUT rated power and below	5.7	≥B	NO APPLICABLE	--	--
Modos de control de la potencia reactiva / Reactive power control modes	5.8	≥B	NO APPLICABLE	--	--
Control de amortiguamiento de oscilaciones / Control of oscillation damping	5.10	≥C	NO APPLICABLE	--	--
Capacidad para soportar huecos de tensión de los MPE conectados por debajo de 110 kV / Capability to withstand voltage grid faults for POC below 110 kV	5.11	≥B	NO APPLICABLE	--	--
Capacidad para soportar huecos de tensión de los MPE conectados por encima de 110 kV / Capability to withstand voltage grid faults for POC above 110 kV	5.11	D	NO APPLICABLE	--	--
Recuperación de la potencia activa después de una falta / Active power recovery after a grid fault	5.11	≥B	NO APPLICABLE	--	--
Inyección rápida de corriente de falta en el punto de conexión en caso de faltas trifásicas) simétricas / Rapid current injection control	5.11	≥B	NO APPLICABLE	--	--
Capacidad de participar en el funcionamiento en isla / Islanding requirements	5.13	≥C	NO APPLICABLE	--	--
(*) Evaluado por / Evaluated by: P: Prueba de conformidad / Test of compliance S: Simulación de conformidad / Simulation of compliance					


**Declaration: It is an accurate translation of the original document.**

El presente Certificado está destinado al uso exclusivo del cliente de Intertek y se entrega en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad y la obligación de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente según el acuerdo, por cualquier pérdida, gasto, o daño ocasionado por el uso de este Certificado. Únicamente el Cliente está autorizado a conceder la copia o distribución de este Certificado. El uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto, o servicio examinado debe ser aprobado previamente por escrito por Intertek.


# Certificate of Conformity

Certificate Number: CN-PV-230100

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong P.R. China
<b>Product:</b>	Grid-Connected PV Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	R6-25K-T3-32, R6-30K-T3-32, R6-33K-T3-32, R6-36K-T3-32, R6-40K-T4-32, R6-50K-T4-32
<b>Brand Name&lt;s&gt;:</b>	
<b>Product Complies with:</b>	UNE 217001:2020 Tests for systems that avoid the discharge of energy to the distribution network
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	220411134GZU-004

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**

**Date: 14 March 2023**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230100.


Model list		R6-50K-T4-32	R6-40K-T4-32	R6-36K-T3-32	R6-33K-T3-32	R6-30K-T3-32	R6-25K-T3-32
PV INPUT	VMAX PV[Vdc]	1100					
	ISC PV[A]	38.4/38.4/38.4/38.4			38.4/38.4		
	MPPT Voltage Range VMPP[Vdc]	180-1000					
	Max. Input Current IMAX [A]	32/32/32/32			32/32/32		
	MPPT Full Power Voltage Range [Vdc]	530-900	500-900	540-900	520-900	500-900	480-900
	Number of MPPT	2					
	String per MPPT	4			3		
	Backfeed Current [A]	0					
	Oversvoltage Category[OVC]	II					
AC Side (ON-Grid)	Rated Output Voltage Ur[Vac]	3L/N/PE,230/400					
	Rated Output Frequency FNETZ [Hz]	50/60					
	Rated Output Power PE [KW]	50	40	36	33	30	25
	Max. Apparent power SEmax [KVA]	50	44	39.6	36.3	33	27.5
	Rated Output Current Ir [A]	3*72.5	3*58.0	3*52.2	3*47.8	3*43.5	3*36.3
	Max. Output Current I <sub>max</sub> [A]	3*75.8	3*66.7	3*60.0	3*55.0	3*50.0	3*41.7
	Power Factor (cosφ)	0.8 leading ~ 0.8 lagging					
	Max. Efficiency	98.8%					
	Euro Efficiency	98.5%					
	THD [V/I](100% full power)	< 3%					
	Acoustic Noise[dB]	< 50					
Oversvoltage Category[OVC]	III						

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230100.

Installation scheme:



Maximum number of inverters to be connected in parallel is:

Using energy meter CHINT DTSU666, maximum number of inverters connected in parallel are 10



# Certificate of Conformity

Certificate Number: CN-PV-220133

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
<b>Product:</b>	PV Grid-connected Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	R6-15K-T2-32, R6-17K-T2-32, R6-20K-T2-32, R6-22K-T2-32, R6-25K-T2-32
<b>Brand Name&lt;s&gt;:</b>	
<b>Product Complies with:</b>	NTS-631:2020 Technical standard for monitoring the compliance of power generating modules according to EU Regulation 2016/631
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	220614052GZU-001

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**  
**Date: 06 July 2022**



PRD N° 306B

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number:CN-PV-220133.

Unit / Type .....	R6-15K-T2-32	R6-17K-T2-32	R6-20K-T2-32	R6-22K-T2-32	R6-25K-T2-32
Hardware version / Serial No. (tested) :	Main Power board: V1.3; Control board: V1.0				
Firmware version / Software version (tested) .....	V1.020				
Full-load MPP DC voltage range [V] .... :	460-900	460-900	480-900	500-900	520-900
Input DC voltage range [V] .....	180-1000				
Input DC current [A] .....	max. 32A x 2				
ISC PV [A] .....	38,4A x 2				
Nominal output AC voltage [V] .....	230/400V (3~ + N + PE, 50/60Hz)				
Max. Output AC current [A] .....	25.0	28.4	33.4	36.7	41.7
Nominal active output power [kW]..... :	15	17	20	22	25
Max. apparent output power [kVA] .... :	16,5	18,7	22,0	24,2	27,5

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-220133.

Requisito / Requirement	NTS	Tipo / Type	Cumplimiento / Complicant	Nombre Entidad Emisora / Name of issuing Entity	Ev. (*)
Modo regulación potencia-frecuencia limitado sobrefrecuencia (MRPFL-O) / Power-frequency regulation mode limited to overfrequency (MRPFL-O)	5.1	≥A	YES (TRF No. 220614052GZU-001)	Intertek	P
Modo regulación potencia-frecuencia limitado-subfrecuencia (MRPFL-U) / Power-frequency regulation mode limited to underfrequency (MRPFL-U)	5.2	≥C	NO APPLICABLE	--	--
Modo regulación potencia-frecuencia (MRPF) / Power-frequency regulation mode (MRPF)	5.3	≥C	NO APPLICABLE	--	--
Control de potencia-frecuencia / Frequency Control	5.4	≥C	NO APPLICABLE	--	--
Capacidad de control y el rango de control de la potencia activa en remote / Active Power Requirements	5.5	≥C	NO APPLICABLE	--	--
Emulación de inercia durante variaciones de frecuencia muy rápidas / Intertia Emualtions	5.6	≥C	NO APPLICABLE	--	--
Capacidad de potencia reactiva a la capacidad máxima y por debajo / Reactive power capabilities at the EUT rated power and below	5.7	≥B	NO APPLICABLE	--	--
Modos de control de la potencia reactiva / Reactive power control modes	5.8	≥B	NO APPLICABLE	--	--
Control de amortiguamiento de oscilaciones / Control of oscillation damping	5.10	≥C	NO APPLICABLE	--	--
Capacidad para soportar huecos de tensión de los MPE conectados por debajo de 110 kV / Capability to withstand voltage grid faults for POC below 110 kV	5.11	≥B	NO APPLICABLE	--	--
Capacidad para soportar huecos de tensión de los MPE conectados por encima de 110 kV / Capability to withstand voltage grid faults for POC above 110 kV	5.11	D	NO APPLICABLE	--	--
Recuperación de la potencia activa después de una falta / Active power recovery after a grid fault	5.11	≥B	NO APPLICABLE	--	--
Inyección rápida de corriente de falta en el punto de conexión en caso de faltas trifásicas) simétricas / Rapid current injection control	5.11	≥B	NO APPLICABLE	--	--
Capacidad de participar en el funcionamiento en isla / Islanding requirements	5.13	≥C	NO APPLICABLE	--	--
(*) Evaluado por / Evaluated by: P: Prueba de conformidad / Test of compliance S: Simulación de conformidad / Simulation of compliance					


This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.




# Certificate of Conformity

Certificate Number: CN-PV-230136

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong P.R. China
<b>Product:</b>	Grid-Connected PV Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	R6-15K-T2-32, R6-17K-T2-32, R6-20K-T2-32, R6-22K-T2-32, R6-25K-T2-32
<b>Brand Name&lt;s&gt;:</b>	
<b>Product Complies with:</b>	UNE 217001:2020 Tests for systems that avoid the discharge of energy to the distribution network
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	220411134GZU-003

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**

**Date: 30 March 2023**



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230136


Model list		R6-25K-T2-32	R6-22K-T2-32	R6-20K-T2-32	R6-17K-T2-32	R6-15K-T2-32
PV INPUT	VMAX PV[Vdc]	1100				
	ISC PV[A]	38.4/38.4				
	MPPT Voltage Range VMPP[Vdc]	180-1000				
	Max. Input Current I <sub>MAX</sub> [A]	32/32				
	MPPT Full Power Voltage Range [Vdc]	520-900	500-900	460-900	460-900	460-900
	Number of MPPT	2				
	String per MPPT	1/1				
	Backfeed Current [A]	0				
	Oversvoltage Category[OVC]	II				
AC Side (ON-Grid)	Rated Output Voltage U <sub>r</sub> [Vac]	3L/N/PE,230/400				
	Rated Output Frequency F <sub>NETZ</sub> [Hz]	50/60				
	Rated Output Power P <sub>E</sub> [KW]	25	22	20	17	15
	Max. Apparent power S <sub>E</sub> <sub>max</sub> [KVA]	27.5	24.2	22	18.7	17
	Rated Output Current I <sub>r</sub> [A]	3*36.2	3*31.9	3*29.0	3*24.6	3*21.7
	Max. Output Current I <sub>max</sub> [A]	3*41.7	3*36.7	3*33.3	3*28.3	3*25.0
	Power Factor (cosφ)	0.8 leading ~ 0.8 lagging				
	Max. Efficiency	98.8%				
	Euro Efficiency	98.5%				
	THD [V/I](100% full power	< 3%				
	Acoustic Noise[dB]	< 50				
	Oversvoltage Category[OVC]	III				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230136

Installation scheme:



Maximum number of inverters to be connected in parallel is:

Using energy meter CHINT DTSU666, maximum number of inverters connected in parallel are 9

